

REVERSE OSMOSIS MODELS EKO 10S RANGE

INDUSTRIAL



System Capacities

- ⊕ The system capacities indicated below are based on feed water with a total dissolved solid (TDS) content of <1500mg/l and a recovery of around 60% - 70%
- ⊕ Capacity will vary according to the feed water TDS and temperature.
- ⊕ The pump operating pressure will vary according to the feed water quality.
- ⊕ Typically pump pressure will be in the range of 10 to 15Bar.

Dimensions

- ⊕ RO unit : 1m (L) and 1m (W)
- ⊕ Overall Height: varies between 1m and 1.35m according to the model.
- ⊕ Sufficient space will be required in front of the unit to allow filter replacement

Models

Model	Nominal Capacity (cu-m/day)	Membranes 4" X 40
EKO 10S-1	6	1
EKO 10S-2	13	2
EKO 10S-3	18	3
EKO 10S-4	25	4

EKO 10S RANGE

INDUSTRIAL

Operating Conditions

Feed Pressure:	1.5 to 4 Bar
Power:	400VAC 50Hz 3 phase
Temperature range:	5°C to 35 °C
Feed pH:	4 to 8

Equipment

The RO unit will be pre-assembled on a stainless steel frame and will include the following main components:

- ⊕ Lowara SV series or equal 316L stainless steel pump complete with 400VAC 3 phase motor
- ⊕ 40"x 4" CSM Membranes or equal
- ⊕ GRP Membrane vessels 300psi
- ⊕ Stainless steel brine control needle valve
- ⊕ Stainless steel brine – feed by- pass control needle valve
- ⊕ IP 65 Electrical Control Enclosure
- ⊕ Microprocessor based Electronic RO Controller
- ⊕ Optional Conductivity monitor
- ⊕ Low pressure pipes & fittings in PVC
- ⊕ High pressure pipes & fittings in 316L stainless steel
- ⊕ Pump low pressure shut off switch
- ⊕ Inlet solenoid valve
- ⊕ Brass flush solenoid valve
- ⊕ SSTL Inlet pressure gauge
- ⊕ SSTL membrane pressure gauge
- ⊕ Plastic Pre-filter housing
- ⊕ Frame for mounting above equipment in stainless steel

Pre-Treatment Information

The membranes used in most reverse osmosis systems, including our EKO 10S range, are spiral wound and made of a polyamide material. This material is not compatible with oxidizing agents such as chlorine that is normally found in tap water. The client needs to make sure that effective pre-treatment efforts are taken to remove any chlorine that may be present in the feed water.

The passages within a membrane are fairly small and un-dissolved materials can become lodged inside the membrane blocking it and reducing its capacity. Adequate filtration is also required.

The reject from the reverse osmosis system has an increased concentration of salts and particularly hardness salts. Care must be taken to ensure that these salts do not precipitate in the membrane as this can lead to an irreversible damage. Depending on the feed water as well as the system recovery, a water softener or anti-scalant chemical injection may be required before the system as part of the pre-treatment.

Contact **TUA Engineering** for assistance on your pre-treatment requirement.